



AURANGABAD MUNICIPAL CORPORATION  
FIRE BRIGADE

TELEPHONE NO-2334000-40 FAX NO-2331444

Outward No: AMC/FIRE/956/2015  
TO

Date 27/11/2015

PRACHARYA  
DEOGIRI GLOBAL ACADEM C.B.S.E  
SCHOOL BUILDING ON C.T.S NO- 18314  
AT STN ROAD .AURANGABAD.

Sub;- Final Fire NOC is issued to the PRACHARYA DEOGIRI GLOBAL  
ACADEM C.B.S.E SCHOOL BUILDING ON C.T.S NO- 18314 AT STN ROAD  
AURANGABAD.

Ref;-1)YOUR Letter dated -27/11/2015.

With reference to the above subject, Final Fire NOC is issued to the PRACHARYA  
DEOGIRI GLOBAL ACADEM C.B.S.E SCHOOL BUILDING ON C.T.S NO- 18314 AT STN ROAD  
AURANGABAD Plot area is 10414.00 sq.meter old built up 1969.35sq.meter&old  
Height of the building is 10.00 meter now additional extra builtup area is 3490.65  
sq.meter Total builtup area is 5460.00sq.meter height of building is 16.05  
meter building has parking+4 Floors.and having width 42.00meter and  
length 58.00 meter

Following Fire prevention and Fire protection & Fighting measures subject to  
the DEOGIRI GLOBAL ACADEM C.B.S.C SCHOOL BUILDING is provided

- 1 open space all around building is provided for free movement of fire tender  
and which will carry 25 tones weight capacity
- 2 over head Fire water tank of 25000 Ltrs, capacity Nos -01 with Main Electric fire pump  
10Hp Nos 01 for building is provided.
- 3 Fire service inlet 6 way incoming is provided
- 4 court yard hydrant points Nos-07 all round the building with fire hose pipe Nos 07 &  
branch Nos-07 is provided
- 5 Two Down comer system with FEH, (Fire exit Hydrat) Nos-08 is provided
- 6 Fire Alarm system No-01 & sprinkler system NO-55 & manual call point No-15 & H00TER  
Nos-15 to whole building is provided
- 7 Two External approach Fire Escape staircase of 2.00 meter width of single flight and  
total 4.00 meter width staircase is provided
- 8 Hose reel of 100 feet on all out lets Nos -08 is provided
- 9 Fire extinguishers Type ABC 06KG Nos -15 & Fire extinguishers CO2 4.5 kg Nos -05 & 22kg  
Nos 02 provided
- 10 Fire fighting system Testing each six Month as July to January Authorised fire  
Agency Certified As per the fire act 2006
- 11 Fire noc is renewed each year

BPMC ACT -1949 section 376, development control Rules of 1983 and MAHARASHTRA Fire  
prevention its Life safety Measures Act 2006 Final FIRE NOC is issued to the  
PRACHARYA DEOGIRI GLOBAL ACADEM C.B.S.E SCHOOL BUILDING ON C.T.S NO- 18314 AT STN ROAD  
AURANGABAD

  
Chief Fire Officer,  
Fire Brigade,  
Municipal Corporation, Aurangaba

Copy:- A D.T.P AMC, Aurangabad





AURANGABAD MUNICIPAL CORPORATION  
FIRE BRIGADE  
TELEPHONE NO-2334000-40FAX NO-2331444

Outward No: AMC/FIRE/200/2015

Date: 09/05/2015

TO  
PRACHARYA  
DEOGIRI GLOBAL ACADEM C.B.S.C  
SCHOOL BUILDING ON C.T.S NO-18314  
AT STN ROAD AURANGABAD.

Sub:- Revised Provisional Fire NOC is issued to the PRACHARYA DEOGIRI  
GLOBAL ACADEM C.B.S.C SCHOOL BUILDING ON C.T.S NO-18314 AT STN  
ROAD AURANGABAD.

Ref:- 1) YOUR Letter dated -04.06.2015.

With reference to the above subject, Revised Provisional Fire NOC is issued to the  
PRACHARYA DEOGIRI GLOBAL ACADEM C.B.S.C SCHOOL BUILDING ON C.T.S NO-18314 AT  
STN ROAD AURANGABAD plot area is 10414.00 sq. meter old built up 1999.35 Sq.  
meter & old Height of the building is 10.00 meter NOW additionl extra **builtup area is  
3490.65 sq. meter Total builtup area is 5460.00 sq. meter height of building is 16.05  
meter building has parking +4 Floors. and having width 42.00 meter and length  
58.00 meter** owner has already paid capitation fees of Rs 25,000/- and noc fees of Rs  
10,000/- in Fire brigade by receipt No-526646 dated .13.02.2013 NOW additionl capitation  
fees of Rs 10,000/- and noc fees of Rs 10,000/- in Fire brigade by receipt No-13657  
dated .13.05.2015

Following Fire Prevention and Fire Protection & Fighting measures subject to the  
DEOGIRI GLOBAL ACADEM C.B.S.C SCHOOL BUILDING shall be provided

- 1 6.00 meter open space all around the building for easy movement of Fire tender with 25 tones load taking capacity shall be provided.
- 2 overhead fire water tank of 25000 Ltrs, capacity with fire pump of suitable capacity for building shall be provided.
- 3 Fire service inlet 6 way incoming shall be provided
- 4 COURT YARD hydrant points of 10 NO all round the building with fire hose pipe/ branch shall provided
- 5 Two down corner system/ Automatic sprinkler system/Manually Operated
- 6 Electric Fire Alarms system/ or shall be provided.
- 7 PARKING area sprinkler system shall be provided
- 8 TWO external approach Fire escape staircase of 2.00 meter width of single flight and total 4.00 meter width staircase shall be Provided
- 9 HOSE reel Of 100 feet on all out lets shall be provided
- 10 Fire Extinguishers CO2/DCP/Water/CO2/Fire buckets/ of suitable quantity shall be provided
- 11 All requirements should be maintained from Authorised fire Agency certified as per the fire act 2006.

MAHRASHTRA FIRE PREVENTION AND LIFE SEFTY ACT 2006 Rule under building construction completed at this stage hence above fire prevention & fire safety measures should be provided after compliance of above point Final Fire Noc will be issued

Chief Fire Officer,  
Fire Brigade,  
Municipal Corporation, Aurangabad.

Copy:- A D.T.P AMC, Aurangabad

# S CUBE INFRASTRUCTURES

Branch Office: C-7, Prozone Trade Centre, Aurangabad, Maharashtra.431006

LICENSE NO: MFS / LA / RF-382 / RD-372

Ref No-12

Date:-06.03.2024

## FORM B

[See section 3(3) and Rule 4(2)]

Six monthly certificates to be given in every January and June by the owner or the occupier for the compliance of the Fire Prevention and Life Safety Measures.

## CERTIFICATE

Certified that I/We have carried out inspection the Fire Prevention and life Safety Measures installed in the Following building or premises,

Namely:

M/s.

PARACHARYA,DEOGIRI GLOBAL ACADEMY C.B.S.E  
SCHOOL BUILDING ON C.T.S NO-18314  
AT STATION ROAD ,AURANGABAD.

We further certify that these installations in the above mentioned building are maintained in good repair and efficient conditions during the period **January 2024 to June 2024** as required under the provisions of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006 (Mah.Sub Rule (2) Of Rule 4-2009). The details of the inspection of installations carried out by me/us are mentioned in the report appended herewith.

Place: Aurangabad

[Note. - Detailed location and postal addresses are to be provided here]



Signature & Address of the Licensed Agency

**S CUBE INFRASTRUCTURES**

C-7, PROZONE TRADE CENTRE

Aurangabad, Maharashtra-431006

LICENSE NO: MFS / LA / RF-382 / RD-372

Annexure: Attached

  
**Dattatraya S. Chavan**  
Principal  
Deogiri Global Academy  
CBSE Affiliation No. 1130664  
Bhagirath Nagar, Railway Station Road,  
Aurangabad - 431005.

Branch Office: C-7, Prozone Trade Centre, Aurangabad, Maharashtra.431006  
Main Office: Shop No.111, Labh Chambers, Station Road, Aurangabad-431001

# S CUBE INFRASTRUCTURES

Branch Office: C-7, Prozone Trade Centre, Aurangabad, Maharashtra.431006  
LICENSE NO: MFS / LA / RF-382 / RD-372

Ref No-12  
Date:-06.03.2024

M/s.  
PARACHARYA,DEOGIRI GLOBAL ACADEMY C.B.S.E  
SCHOOL BUILDING ON C.T.S NO-18314,  
AT STATION ROAD ,AURANGABAD.

## Annexure

Sr.No.	Particulars	Quantity	UOM
1	ELECTRIC FIRE PUMP	01	Nos.
2	6 WAY INLET	01	Nos.
3	HYDRENT	07	Nos.
4	SPRINKLERS	55	Nos.
5	MANUAL CALL POINT	15	Nos.
6	HOOTER	15	Nos.
7	HOSE REEL	08	Nos.
8	FIRE EXTINGUISHER ABC - 6KG	15	Nos.
9	FIRE EXTINGUISHER CO <sub>2</sub> - 4.5KG	05	Nos
10	FIRE EXTINGUISHER CO <sub>2</sub> - 22KG	02	Nos

The above annexure are tested and found in satisfactory working condition.



  
Dattatraya S. Chavan  
Principal  
Deogiri Global Academy  
CBSE Affiliation No. 1130664  
Bhagirath Nagar, Railway Station Road,  
Aurangabad - 431005.

Signature & Address of the Licensed Agency

**S CUBE INFRASTRUCTURES**  
C-7, PROZONE TRADE CENTRE  
Aurangabad, Maharashtra-431006  
LICENSE NO: MFS / LA / RF-382 / RD-372

Branch Office: C-7, Prozone Trade Centre, Aurangabad, Maharashtra.431006  
Main Office: Shop No.111, Labh Chambers, Station Road, Aurangabad-431001